

EU Declaration of Conformity

Regulation (EU) 2016/425

1. This EU Declaration of conformity refers to the following products:

Product Name	Model	Classification/Type	Reference Number
FFP2 Protective Particulate Respirators	ENM 712-0	CAT III	712001110 712005110

2. Manufacturer's name and address is as below:

Company Name	En Ecza Deposu İlaç Medikal Özel Sağlık Hizmetleri İnşaat Taahhüt Ticaret A.Ş.
Address	Saray Mahallesi Gıdacılar Caddesi 3670 Ada 2 Parsel Kahramankazan ANKARA/ TURKEY
AB Authorized Representative	ENMED B.V.
Address	Oudeweg 109A 2031 CC Haarlem Amsterdam NETHERLANDS

3. The Conformity assessment according to the essential requirements has been done by Easepal according to

EU Community Legislation Personal Protective Equipment (PPE) Regulation (EU) 2016/425 Annex VII in connection with Annex V (Module C2) Certificate Number: 91-22-01-01 (White, Black, Normal Size, Small Size

Harmonised standart:

EN 149:2001 + A1:2009 Respiratory Protective Devices -Filtering Half Masks to Protect Against Particles - Requriements, Testing, Marking (FFP2 NR)

Declaration Type:

MNA LABORATUVARLARI SAN. TİC. LTD. ŞTİ.

NB Number: 2841

This declaration is

valid until:

This certificate is initially issued will be valid or 1 years from the issue date.

Place and Date of Issue:

Ankara / TURKEY

Date: 05.02.2022

Company Sign:

EN ECZA DEPOSU İLAÇ MEDİKAL ÖZEL SAĞLIK HİZM. A.Ş.

EN ECZA DEPOSU ILU MEDIKAL ÖZEL SAĞUK HİZMETLERİ İNŞAAT TAAH HUTU ÇRET ANONIM ŞİRKETİ Adres Albur Mah 316 M. MODILAÇI NO BIR MEDIRMERSIN Adres NO. 12943 MAYAT İSUKLAL VO. 3350/076767 MERSIS NO. 3350/07675000 1 TÜ. SICI. NO. 51525

Tel: 0324 357 56 44 Fax: 0324 357 58 44



ENM 712-0 PROTECTIVE PARTICULATE RESPIRATORS WITHOUT VALVE (NORMAL SIZE & SMALL SIZE)





Fold design enables product to be easily stored when not in use. Diamond-shaped front allows the respirator to maintain its shape in hot humid environments.

Single loop strap allows easy adjustment on the face and head.

ENM 712-0 is Particulate Respirators provide effective respiratory protection for use in industries where workers will be exposed to dust particles and/or non-volatile liquid particles.

Specification

Staps : Thermoplastic Elastomer Nosefoam** : Polyurethane

Nose Clip : Steel/ Plastic Size : Normal Size, Small Size

Color : White, Black



ENM 712-0 PROTECTIVE PARTICULATE RESPIRATORS WITHOUT VALVE (NORMAL SIZE & SMALL SIZE)

Approvals

CE approved under PPE Directive (EU) 2016/425, Category III

Standards

These products meet the requirements of recently amended European Standard EN149:2001 + A1:2009, filtering facepiece respirators for use against particles. They should be used to protect the wearer from solid and non-volatile liquid particles only.

Products are classified by filtering efficiency and maximum total inward leakage performance (FFP1, FFP2 and FFP3), also by usability and clogging resistance.

Performance tests in this standard include filter penetration; extended exposure (loading) test; flammability; breathing resistance and total inward leakage. Reusable products are also subjected to cleaning, storage and mandatory clogging resistance tests

(clogging is optional for non reusable products). A full copy of

EN 149:2001+A1:2009 can be purchased from your national standards body. Designations:

R = Reusable

NR = Non reusable (single shift use only)













Storage and Disposal

- Store in dry, clean conditions in original packaging, away from direct sunlight, sources of high temperature, and solvent vapours
- Store within the temperature range -5°C to +25°C and with relative

humidity below 80%

- Expected shelf life is three years from date of manufacture when stored as stated
- Replace garments if damaged, heavily contaminated or in accordance with local work practice or regulations
- Handle and dispose of contaminated garments with care and in accordance with applicable regulations.

Fitting Instructions

- **1.**With the respirator closed, shape the nosepiece as shown.
- **2.**Open respirator, press in the central front panel and pinch the two points together as shown.
- **3.**Cup respirator in one hand with open side towards face. Take both straps in other hand. Hold respirator under ehin, with nosepiece up, and pull straps over head.
- **4.**Locate the upper strap across the crown of the head and the lower strap below the ears. Straps must not be twisted.
- **5.**Using both hands, mould noseclip to the shape of the lower part of the nose to ensure a close fit and good seal. Pinching the noseclip using only one hand may result in less effective respirator performance.
- **6.**The seal of the respirator on the face should be fit-checked before entering the workplace.

Fit Check

1.Cover the front of the respirator with both hands being careful not to disturb the fit of the respirator.

2.a) UNVALVED respirator - EXHALE sharply;

3.If air leaks around the nose, re-adjust the noseclip to eliminate leakage. Repeat the above fit check.

4.If air leaks at the respirator edges, work the straps back along the sides of the head to eliminate leakage. Repeat the above fit check.

If you CANNOT achieve a proper fit DO NOT enter the hazardous area. See your supervisor.

Sarah Mah. Gidacilar Cad. No:18 Kahramankazan ANKARA TURKIYE

v.enmedglobal.com ENM~712 – 0



ENM712-0 PROTECTIVE PARTICULATE RESPIRATORS WITHOUTVALVE (NORMAL SIZE & SMALL SIZE)

Warning and Limitation of Use

- 1. Always be sur e that the complete product is: Suitable for the application; Fitted correctly; Worn during all periods of exposure; Replaced when necessary.
- 2. Proper selection, training, use and appropriate maintenance are essential in order tor the product to help protect the wearer from certain airborne contaminants.
- 3. Failure to follow all instructions on the use of these respiratory protection products and/or failure to properly wear the complete product during all periods of exposure may adversely affect the wearer's health, lead to severe or life threatening illness or permanent disability.
- 4. For suitability and proper use follow local regulations, reler to all information supplied or contact a safety professional.
- 5. Before use, the wearer must be trained in use of the complete product in accordance with applicable Health and Safety standards.
- 6. These products do not contain components made from natural rubber latex.
- 7. These products do not protect against gases/vapours.
- 8. Do not use in atmospheres containing less than 19.5% oxygen. (Individual countries may apply their own limits on oxygen deficiency. Seek advice if in doubt).
- 9. Do not use tor respiratory protection against atmospheric contaminants/ concentrations which are unknown or immediately dangerous to life and health (IDLH).
- 10. Do not use with beards or other facial hair that may inhibit contact between the face and the product thus preventing a good seal.
- 11. Leave the contaminated area immediately if:
- a) Breathing becomes difficult.
- b) Dizziness or other distress occurs.
- 12. Discard and replace the respirator it it becomes damaged, breathing resistance becomes excessive or at the end of the shift.
- 13. Never alter, modify or repair this device.

Applications

These respirators are suitable for use in concentrations of solid and non-volatile liquid particles up to the following limits:

Model	EN 149+A1 Classification	Exhalation Valve	Threshold Limit Value, TLV
ENM - 712-0	FFP2 NR	Unvalved	12
ENM - 712-1	FFP2 NR	Valved	12

FILTERING MASK PERFO	RMANCES					
Classification	Penetration of Filter Material by an Aerosol (the following filter penetration parameters shall not be exceeded)	Maximum Permitted Breathing Resistance applicable to both valved and valvless filtering half-masks (mbar)				
Classification	Test aerosol made of Sodium chloride - Paraffin oil	Inhalat	on flow	Exhalation flow		
	95I/min % Max.	30 l/min	95 l/min	160 l/min		
FFP2	6 %	0,7	2,4	3,0		



ENM712-0 PROTECTIVE PARTICULATE RESPIRATORS WITHOUTVALVE (NORMAL SIZE & SMALL SIZE)

SELECTION (GUIDE	FFP1	FFP2	FFP3	Organic Vapour	Acid Gas	Welding
Painting,	Solvent-Based - brush / roller applied			•	•		
Varnishing, Spraying,	Solvent-Based - spray applied						
Coating, Mixing	Water-Based - brush / roller / spray applied			•	•		
MIXIIIG	Wood Preservatives			•	•		
	Powder Coating			•			
Sanding,	Rust, most Metals, Filler, Concrete, Stone	•					
Stripping, Grinding,	Cement, Wood, Steel,		•				
Grinding, Cutting, Drilling	Paints, Varnish, Anti-rust coating		•				
Diming	Stainless Steel, Anti-fouling varnish			•			
	Resins, Reinforced plastics (carbon / glass fibre)		•	•			
Construction /	Scabbling, Shot-creting (concrete dust)	•	•	•			
Maintenance	Plastering, Rendering, Cement mixing	•	•	•			
	Demolition	•	•				
	Groundwork, Earth moving, Piling, Underpinning		•	•			
	Spray foam, Loft Insulation		•	•			
Metal working /	Welding, Soldering		•	•			
Foundries	Electro-plating		•	•			
	Finishing, Slotting, Drilling, Riveting, Machining		•	•			
	Oxyacetylene cutting		•	•			
	Molten metal handling, Smelting		•	•		0	
Cleaning /	Disinfection, Cleaning		•	•	•	•	
Waste Removal	Waste removal		•	•	•		
	Asbestos handling			•			
	Asbestos removal						
Allergens /	Pollen, Animal dander	•					
Biohazards	Mould / Fungus, Bacteria**, Viruses		•	•			
	**Tuberculosis			•			
	Diesel exhaust / Smoke		•				
Agriculture /	Handling infected animals, Culling		•	•	•		
Forestry	Feeding livestock, Cleaning sheds / harvesters	•	•	•			
	Straw chopping, Composting, Harvesting		•	•			
	Pesticides, Insecticides (crop spraying)		•	•	•		
Mining /	Tunnelling, Drilling, Grinding, Excavation		•	•			
Quarrying	Pumping, Dredging, Washing		•	•			
	Cutting, Sawing		•	•			
	Changing Filters		•	•			
Other	Inks, Dyes, Solvents, Chemicals		•	•	•		
Industrial Applications	Powdered Additives / Chemicals		•	•	•		
	Pharmaceuticals		•	•	•		
	Rubber / Plastics processing		•	•	•		
	Oil and Gas Extraction / Processing		•	•	•	•	
	Pottery, Ceramics						
	Wood / Paper Mills		•				

Sarah Mah. Gidacilar Cad. No:18 Kahramankazan ANKARA TURKIYE

www.enmedglobal.com

ENM 712-0
Technical Datasheet



CONFORMITY TO TYPE BASED ON INTERNAL PRODUCTION CONTROL PLUS SUPERVISED PRODUCT CHECKS AT RANDOM INTERVALS (MODULE C2)

MODÜL C2 - ÜRETİMİN DÂHİLÎ KONTROLÜ VE ÜRÜNÜN RASTGELE ARALIKLARLA DENETIMLI MUAYENESINE DAYALI TIPE UYGUNLUK

Belge No / Certificate No

Belgelendirme Tarihi - Bir Sonraki Belge Tarihi /

Certification Date / Certificate Validity Date

Ürün Adı /Modeller / Product Name / Models

Belge Geçerlilik Tarihi / Document Validity Period

Firma Unvanı ve Adresi /

Direktifi / Directive

Company Name and Address

: 91-22-01-01-R01

: 05.02.2022-31.01.2023

: 1 yıl / 1 year

: EN ECZA DEPOSU İLAÇ MEDİKAL ÖZEL SAĞLIK HİZMETLERİ İNŞAAT TAAHHÜT TICARET A.Ş.

Saray Mahallesi, Gıdacılar Caddesi, No:18, Kahramankazan/ANKARA

: ENM-712-0

: 2016/425 REGULATION

: C2 MODÜLÜ/ KATEGORİ III MODULE C2 / CATEGORY III

Modülü/Kategori / Module / Category Teknik Değerlendirme Rapor No/

Technical Evaluation Report No. Ürün Tipi / Product Type:

: MNA 91-22-01-R01

EN 149:2001+ A1:2009 Solunumla ilgili koruyucu cihazlar- Parçacıklara karşı koruma amaçlı filtreli yarım maskeler/ Respiratory protective devices - Filtering half masks to protect against particles

Ürünün Malzeme Bilgisi / Product Material Information: ENM-712-0 model ürünleri kumaş, elastik kayış, burun klipsi, filtre katmanı kullanılarak imal edilmiştir. / ENM-712-0 products are manufactured using fabric, elastic strap, nose clip, filter layer.

Revizyon nedeni / Reason for revision: Farklı renk ve beden eklenmiştir./ Different size and color have been added.

Volkan AKIN 05.02.2022 Karar Verici / Approver

Okan AKEL 05.02.2022

Sirket Müdürü / General manager







AB Tip İnceleme Sertifikası EU Type-Examination Certificate

Belge No / Certificate No
Belgelendirme Tarihi - Bir Sonraki Belge Tarihi /
Certification Date / Certificate Validity Date
Belge Geçerlilik Tarihi / Document Validity Period
Firma Unyanı ve Adresi /

Company Name and Address

Ürün Adı /Modeller / *Product Name / Models* Direktifi / *Directive* Modülü/Kategori / *Module / Category*

Teknik Değerlendirme Rapor No/ Technical Evaluation Report No Ürün Tipi / Product Type: : 91-22-01-R01

: 05.02.2022-12.01.2027

: 5 yıl / 5 years

: EN ECZA DEPOSU İLAÇ MEDİKAL ÖZEL SAĞLIK HİZMETLERİ İNŞAAT TAAHHÜT TİCARET A.Ş.

Saray Mahallesi, Gıdacılar Caddesi, No:18, Kahramankazan/ANKARA

: ENM-712-0

: 2016/425 REGULATION

: B MODÜLÜ/ KATEGORİ III MODULE B / CATEGORY III

: MNA 91-22-01-R01

- EN 149:2001+ A1:2009 Solunumla ilgili koruyucu cihazlar - Parçacıklara karşı koruma amaçlı filtreli yarım maskeler/ *Respiratory protective devices - Filtering half masks to protect against particles*

Ürünün Malzeme Bilgisi / *Product Material Information*: ENM-712-0 model ürünleri kumaş, elastik kayış ve filtre katmanı kullanılarak imal edilmiştir./ ENM-712-0 model products are manufactured using fabric, elastic strap, filter layer.

Revizyon nedeni / Reason for revision: Farklı renk ve beden eklenmiştir./ Different size and color have been added.

Volkan AKIN 05.02.2022 Karar Verici / Approver

Okan AKEL 05.02.2022 Şirket Müdürü / General managet



MNA Laboratuvarları San. Tic.Ltd .Şti Adres: Küçükbakkalköy Mahallesi Yenidoğan Cad.No:21 Ataşehir/ İstanbul Tel: 0216 574 07 08 Faks: 0216 575 13 31 www.mnalab.com



ATTACHMENTS (91-22-01-R01)

To certify the PPE product at Category III level, C2 or D module is accompanied by applying one of the conformity assessment methods along with the EU Type Examination (Module B).

Model: ENM-712-0

PPE SPECIFICATION	PERFORMANCE LEVELS			
Classification	FFP2			
Reusable / Single Shift Use	NR			

PPE produced as a single unit to fit an individual user, all the necessary instructions for manufacturing such PPE on the basis of the approved basic model:


MNA LABORATORIES SAN. TIC. LTD. \$TI declares that the above-mentioned product meets the requirements of the directive according to the EU Directive 2016/425, the safety of the product is covered by the conditions and use specified in this certificate and in the technical file.

Or Condition of Storage

MNA Laboratuvarları San. Tic.Ltd .Şti Adres: Küçükbakkalköy Mahallesi Yenidoğan Cad.No:21 Ataşehir/ İstanbul Tel: 0216 574 07 08 Faks: 0216 575 13 31 <u>www.mnalab.com</u>



ATTACHMENTS (91-22-01-R01)



DOCUMENTS IN THE TECHNICAL FILE

- Basic Health Safety Requirements
- Risk Assessment
- Test Reports
- Technical Report

MNA Laboratuvarları San. Tic.Ltd .Şti Adres: Küçükbakkalköy Mahallesi Yenidoğan Cad.No:21 Ataşehir/ İstanbul Tel: 0216 574 07 08 Faks: 0216 575 13 31 <u>www.mnalab.com</u>



TECHNICAL EVALUATION REPORT (91-22-01-R01)

Report No

: 91-22-01-R01

Report Date

: 05.02.2022

Application No

: 91-22-01

1. COMPANY INFORMATION:

EN ECZA DEPOSU İLAÇ MEDİKAL ÖZEL SAĞLIK HİZMETLERİ İNŞAAT TAAHHÜT TİCARET A.Ş. Saray Mahallesi, Gıdacılar Caddesi, No:18, Kahramankazan/ANKARA


2. PPE INFORMATION:

Disposable and non-sterile half mask made of particulate protection fitler material.

3. PPE TYPE IDENTIFICATION

EN 149:2001+A1:2009 Respiratory protective devices – Filtering half masks to protect against particles - Requirements, testing, marking

4. PPE PICTURES



ENM-712-0



TECHNICAL EVALUATION REPORT (91-22-01-R01)

5. PPE DIMENSIONS:

ENM-712-0 model has been found to be produced using standard and small sizes.

6. PPE PRODUCT MATERIAL INFORMATION:

The product is made of elastic strap, nonwoven fabric on the outer and inner layers and fitler material on the middle layer.

7. ESSENTIAL HEALTH AND SAFETY REQUIREMENTS

- A visual inspection was made according to EN 149:2001 +A1:2009 for ergonomics.
- Protection levels and degrees are defined by the manufacturer.
- Suitable construction materials were determined by visual inspection according to EN 149:2001 +A1:2009.

8. ANALYSIS AND EVALUATIONS:

EN 149:2001 +A1:2009

TESTS	PARAMETER	PERFORMANCE LEVELS FFP1 FFP2 F	FP3	RESULTS	PERFORMANCE LEVELS	EVALUATION
Part 7.3 Visual inspection	Shall also the marking supplied by the manu		ation	Appropriate	-	PASS
Banned Azo Dyes	< 30 mg/kg			< 5 mg/kg	-	PASS
Part 7.4 Packaging	for sale packaged in a are protected against	ticle filtering half mask shall be offered sale packaged in such a way that they protected against mechanical damage contamination before use.			-	PASS
Part 7.5 Material	When conditioned in accordance 8.3.1 & 8.3.2 the particle filter half mask shall not collapse.			Appropriate	-	PASS
Part 7.6 Cleaning and disinfecting	After cleaning and disinfecting the re-usable particle filtering half mask shall satisfy the penetration requirement of the relevant class.			Not applicable	-	Not applicable
Part 7.7 Practical performance		o negative comments should be made by the test subject regarding any of the criteria valuated.			-	PASS
Part 7.8 Finish of parts	Parts of the device contact with the weard edge or burrs.			Appropriate	-	PASS

TESTS	PARAMETER	PERFORMANCE LEVELS		RESULTS	PERFORMANCE LEVELS	EVALUATION	
		FFP1	FFP2	FFP3			
Part 7.9.1 Total inward leakage	At least 46 out of the 50 individual exercise result	<25	<11	<5	See the table below	FFP2	PASS

MNA LABORATUVARLARI SAN. TİC, LTD, ŞTİ.

MNA LABORATUVARLARI

TECHNICAL EVALUATION REPORT (91-22-01-R01)

At least 8 out of the	<22	<8	<2	See the table	FFP2	PASS	
10 individual wearer				below			
arithmetic means							

Total Inward Leakage (%)										
	Exercise 1	Exercise 2	Exercise 3	Exercise 4	Exercise 5	Average				
Subject 1 (As received)	3,9	4,2	4,5	3,8	3,5	4,0				
Subject 2 (As received)	6,8	5,9	7,0	5,9	5,7	6,3				
Subject 3 (As received)	4,5	4,2	5,2	5,0	4,4	4,7				
Subject 4 (As received)	4,2	4,0	3,5	4,5	4,6	4,2				
Subject 5 (As received)	4,6	5,0	5,2	5,4	4,7	5,0				
Subject 6 (After temperature conditioning)	3,9	3,8	3,4	5,0	5,1	4,2				
Subject 7 (After temperature conditioning)	5,5	5,1	6,4	4,9	6,2	5,6				
Subject 8 (After temperature conditioning)	6,8	7,2	6,6	6,4	4,9	6,4				
Subject 9 (After temperature conditioning)	3,5	3,6	2,9	2,9	2,7	3,1				
Subject 10 (After temperature conditioning)	4,5	5,3	5,2	4,1	4,5	4,7				

Subject facial dimensions

Subject	Face Length (mm)	Face Width (mm)	Face Depth (mm)	Mouth Width (mm)	
1	133	132	132	65	
2	125	144	116	67	
3	126	135	124	75	
4	123	133	134	74	
5	117	135	122	73	
6	122	142	133	66	
7	113	132	114	75	
8	135	123	123	65	
9	122	135	133	74	
10	135	142	125	83	

TESTS PARAMETER	PARAMETER	PERFORMANCE LEVELS		RESULTS	PERFORMANCE LEVELS	EVALUATION	
	FFP1	FFP2	FFP3				
Part 7.9.2 Penetration of filter	Sodium chloride, 95 L/min %, max	% 20	% 6	% 1	See the table below	FFP2	PASS
material	Paraffin oil, 95 L/min %, max	% 20	%6	%1	See the table below	FFP2	PASS

Penetration of filter material	Sodium Chloride (%)	Paraffin Oil (%)	
As received	1,2	1,6	
As received	1,4	1,5	
As received	1,3	1,5	



TECHNICAL EVALUATION REPORT (91-22-01-R01)

After the simulated wearing treatment	1,2	1,7
After the simulated wearing treatment	1,2	1,8
After the simulated wearing treatment	1,5	1,5
Mechanical strength and temperature conditioning (120 mg)	1,8	2,2
Mechanical strength and temperature conditioning (120 mg)	1,9	2,1
Mechanical strength and temperature conditioning (120 mg)	1,9	2,2

TESTS	PARAMETER PERFORMANCE LEVELS				RESULTS	PERFORMANCE LEVELS	EVALUATION
		FFP1	FFP2	FFP3			
Part 7.10	Materials shall not b	e know	n to be	likely to	Appropriate	-	PASS
Compatibility	cause irritation or any other adverse effect to						
with skin	health						
Part 7.11	Mask shall not burn o	r not to	continu	e to burn	Flame not	-	PASS
Flammibility	for more than 5 s				seen		
Part 7.12	Shall not exceed an av	erage c	f % 1		0,80	-	PASS
Carbondioxide					0,78		(Sa. Agamangan and
content of the					0,85		
inhalation air							
Part 7.13	It can be donned and	remove	d easily		Appropriate	-	PASS
Head harness							
Part 7.14	The field of vision sha	II accept	able in	practical	Appropriate	-	PASS
Field of vision	performance test.						
Part 7.15	It shall withstand axia	Illy a te	nsile for	rce of 10	Not applicable	-	Not
Exhalation	N apply for 10 s.						applicable
valve(s)	If fitted, shall continu						
	after a continuous e		on flow	of 300			
	L/min over a period of	f 30 s.					

TESTS PARAMETER	PARAMETER	PERFORMANCE LEVELS			RESULTS	PERFORMANCE LEVELS	EVALUATION
	FFP1	FFP2	FFP3				
Part 7.16 Breathing	Inhalation 30L/min	0,6 mbar	0,7 mbar	1,0 mbar	See the table below	FFP2	PASS
Resistance	Inhalation 95L/min	2,1 mbar	2,4 mbar	3,0 mbar	See the table below	FFP2	PASS
	Exhalation 160L/min	3,0 mbar	3,0 mbar	3,0 mbar	See the table below	FFP2	PASS

Breathing Resistance (mbar)	Inhalation 30L/min	Inhalation 95L/min	
As received	0,5	1,6	
As received	0,5	1,6	
As received	0,4	1,5	
After temperature conditioning	0,5	1,6	
After temperature conditioning	0,5	1,5	
After temperature conditioning	0,4	1,5	
After the simulated wearing treatment	0,5	1,5	
After the simulated wearing treatment	0,5	1,6	
After the simulated wearing treatment	0,4	1,5	



TECHNICAL EVALUATION REPORT (91-22-01-R01)

Breathing Resistance 160L/min (mbar)	Facing directly ahead	Facing vertically upwards	Facing vertically downwards	Lying on the left side	Lying on the right side
As received	2,8	2,7	2,8	2,8	2,7
As received	2,7	2,8	2,7	2,7	2,8
As received	2,7	2,7	2,7	2,7	2,7
After temperature conditioning	2,7	2,7	2,7	2,7	2,8
After temperature conditioning	2,8	2,7	2,8	2,7	2,7
After temperature conditioning	2,8	2,7	2,8	2,7	2,8
After the simulated wearing treatment	2,8	2,8	2,7	2,7	
After the simulated wearing treatment	2,7	2,7	2,7	2,7	2,8
After the simulated wearing treatment	2,7	2,8	2,7	2,8	2,8

TESTS	PARAMETER	PERFORMANCE LEVELS			RESULTS	PERFORMANCE LEVELS	EVALUATION
		FFP1	FFP2	FFP3			
Part 7.17 Clogging	After clogging the inhalation resistances shall not exceed. (valved)	4 mbar	5 mbar	7 mbar	Not applicable	-	Not applicable
	The exhalation resistance shall not mbar at 160 L/ min continuous flow.				Not applicable	-	Not applicable
	After clogging the inhalation and exhalation resistances shall not exceed. (valveless)	3 mbar	4 mbar	5 mbar	Not applicable	-	Not applicable
Part 7.18 Demountable part	All demountable parts (if fitted) shall be readily connected and secured were possible by hand.				Not applicable	_	Not applicable

9. DECISION PROPOSAL

Analysis and examinations ENM-712-0 model coded personal protective equipment; Respiratory Protective Devices EN 149:2001 +A1:2009- Filtered Half Masks for Protection Against Particles - Properties, Experiments and Marking standards are evaluated. It is recommended to be certified at the performance levels specified as a result of technical evaluations.

10. ATTACHMENTS

- Basic Health Safety Requirements
- Risk Assessment
- Test Report (M-2021-01815, M-2022-0149)

User Instruction

CONTROLLER

: VOLKAN AKIN

SIGNATURE

:

DATE

: 05.02.2022